
Failure or lack of lockout and tag out
4.7.c Isolation devices identified
Procedure
4.6.a Lockout devices
Installation/Equipment
4.6.f Lockout tags
Installation/Equipment
4.7.a lockout and tag out procedures
Installation/Equipment
4.7.b lockout matrix
Installation/Equipment
4.6.g System to manage the isolation and lockout of electrical energy stages
Installation/Equipment
Lockout method / procedure failure
4.7.a lockout and tag out procedures
Procedure
4.7.b lockout matrix
Procedure
4.6.g System to manage the isolation and lockout of electrical energy stages
Installation/Equipment
Lack of procedure or procedure did not provide for lockout
4.7.a lockout and tagout procedures
Procedure
4.7.b lockout matrix
Procedure
Lack or Failure in the lockout efficiency test (zero energy)
4.7.a.IV Procedure for testing the efficiency of the lockout (zero energy)
Procedure
4.6.g System to manage the isolation and lockout of energy stages
Installation/Equipment
Failure in communication between working groups
4.7.i Only one authorized professional designated to confirm the lockout
Procedure
4.7.k.I Exclusive lockout
Procedure
Failure of work planning
4.7.i Only one authorized professional designated to confirm the lockout
Procedure
Lack or failure to lockout potential gravitational energy source
4.7.h Targout and lockout of gravitational energy
Procedure
Failure to make a temporary change to the zero energy
4.7.k Procedure for change of energy state
Procedure
Failure to reset protection devices / integrity of safety conditions
4.7.m Procedures for the removal of locks and tags
Procedure
Lack of training
4.8.a Training in prevention of Risks in Lockout, Tagout and Zero Energy
Training
Energy
Event: Exposure to energy
Personal protective equipment
Emergency response plan
Lesion
Personal protective equipment
Emergency response plan
Fatality